

Ducha WATERS Therapy: eliminación del cloro residual

Once mediciones hasta 10.000 litros acumulados · Korea Testing & Research Institute (KTR) · informe nº TAH-000911 (2011)

DATOS DEL DOCUMENTO

Laboratorio	Korea Testing & Research Institute (KTR) — Wolgot-myeon, Gimpo-si, Gyeonggi-do (Corea del Sur)
Nº de informe	TAH-000911 · muestras recibidas el 08/02/2011 · ensayo finalizado el 23/02/2011
Solicitante	Waters (Corea del Sur) — fabricante · a nombre de Kyung-Suk Bae
Muestra ensayada	Ducha WATERS Therapy
Firmado por	Ju-Hee Lee (elaboración) · Jun-Hee Lee, director técnico
Resultado	0,0 mg/l de cloro residual en los diez puntos de agua filtrada , frente a 0,8 mg/l del agua de red de referencia

EL ENSAYO

Concepto	Contenido
Qué se midió	El cloro residual del agua en once puntos de medición : el agua de red sin filtrar, el agua filtrada al inicio del uso y después de cada 1.000 litros acumulados, hasta 10.000 litros
Método de ensayo	<i>Standard methods for the examination of environmental pollution (drinking water): 2010</i> — método normalizado coreano para el análisis de agua de consumo

RESULTADOS · cloro residual en mg/l · volumen acumulado filtrado por la ducha

Muestra	Cloro residual	Muestra	Cloro residual
Agua de red sin filtrar	0,8	5.000 litros	0,0
Al inicio del uso	0,0	6.000 litros	0,0
1.000 litros	0,0	7.000 litros	0,0
2.000 litros	0,0	8.000 litros	0,0
3.000 litros	0,0	9.000 litros	0,0
4.000 litros	0,0	10.000 litros	0,0

ALCANCE DEL INFORME

Concepto	Contenido
Quién preparó las muestras	El propio informe indica que todas las muestras de agua fueron preparadas y aportadas por el cliente . El laboratorio analizó esas muestras; no realizó el paso del agua por la ducha
Finalidad declarada	Control de calidad (<i>Quality Control</i>)
Alcance de los resultados	Se refieren exclusivamente a las muestras y a la denominación de muestra facilitadas por el cliente

Conclusión del ensayo. El agua de red de referencia contenía **0,8 mg/l de cloro residual**. En el agua filtrada por la ducha **no se detectó cloro en ninguno de los diez puntos de medición**: 0,0 mg/l desde el primer uso y en cada tramo de 1.000 litros **hasta los 10.000 litros acumulados**.

El valor de 0,8 mg/l del agua de referencia está dentro del intervalo habitual del agua de red clorada. El interés del ensayo está en la serie completa: la ausencia de cloro se mantiene a lo largo de los 10.000 litros, sin pérdida de eficacia entre el primer punto y el último.

Aviso legal. Las páginas siguientes reproducen el informe emitido por su autor en el idioma y el formato originales. La presente ficha es una **traducción libre al español elaborada por Ecovidiasolar (www.ecovidiasolar.es)** con fines meramente informativos: no tiene carácter oficial ni jurado, no ha sido revisada ni validada por el emisor y no sustituye al documento original, que es el único válido. En caso de discrepancia entre ambos textos prevalece el original. Los datos se refieren exclusivamente a los productos y muestras identificados en él, y no constituyen una declaración nutricional o de propiedades saludables en el sentido del Reglamento (CE) nº 1924/2006.



YOUR PARTNER FOR THE BEST QUALITY

TEST REPORT

7-6, Gomak-Ri, Wolgot-Myeon, Gimpo-Si, Gyeonggi-Do, KOREA

TEL 82-31-999-3000

FAX 82-31-999-3001

Report No : TAH-000911

Receipt Date : Feb.08.2011

Client : Kyung-Suk Bae

Test Completion Date : Feb.23.2011

WATERS

#516, Dangha-Dong, Seo-Gu, Incheon-Si, Korea.

Sample : WATERS Therapy Shower

TEST RESULTS

TEST ITEM	UNIT	SAMPLE	RESULT	TEST METHOD
Residual Chlorine	mg/L	Raw water	0.8	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	Initial	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	1000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	2000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	3000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	4000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	5000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	6000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	7000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010

- Next Page -

Ju-Hee Lee

Prepared by Ju-Hee Lee
Tel: +82-31-999-3153
E-mail: juheelee@ktr.or.kr

Ju-Hee Lee

Reviewed by Jun-Hee Lee
Technical Manager
E-mail: ljh554@ktr.or.kr

Feb.23.2011

Korea Testing & Research Institute

President

1 of Total 2 Page(s)

KTRI KOREA TESTING & RESEARCH INSTITUTE

전자문서본(Electronic)





YOUR PARTNER FOR THE BEST QUALITY

TEST REPORT

7-6, Gomak-Ri, Wolgot-Myeon, Gimpo-Si, Gyeonggi-Do, KOREA

TEL 82-31-999-3000

FAX 82-31-999-3001

Report No : TAH-000911

Receipt Date : Feb.08.2011

Client : Kyung-Suk Bae

Test Completion Date : Feb.23.2011

WATERS

#516, Dangha-Dong, Seo-Gu, Incheon-Si, Korea.

Sample : WATERS Therapy Shower

TEST RESULTS

TEST ITEM	UNIT	SAMPLE	RESULT	TEST METHOD
Residual Chlorine	mg/L	8000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	9000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010
Residual Chlorine	mg/L	10000L	0.0	Standard methods for the examination of environmental pollution(drinking water) : 2010

* All water samples was made and provided by client.

USAGE : QUALITY CONTROL

NOTE : 1. The test results on this test report are only limited to the samples and sample names provided by the customer and KTR do not guarantee the quality of all products of the customer.
2. This test report shall not be used for public relation, advertisement, lawsuit and any other purposes outside the scope of its defined usage.

Prepared by Ju-Hee Lee
Tel: +82-31-999-3153
E-mail: juheeleee@ktr.or.kr

Reviewed by Jun-Hee Lee
Technical Manager
E-mail: ljh554@ktr.or.kr

Feb.23.2011

Korea Testing & Research Institute

President

2 of Total 2 Page(s)

전자문서본(Electronic)



KTR KOREA TESTING &
RESEARCH INSTITUTE